

BBPUD 2025 Annual Consumer Confidence Report

1 Primary Constituents															Typical Source		CONTACT US
Microbiological Contaminants	MCL	PHG or MCLG	Average	Met Regulation?	Highest # of Detections	# of Months in Violation		Notes									For more information about water quality or to report a water quality concern, call 707-875-3332 or visit www.bodegabaypubd.com.
Total Coliform in Distribution System	<1 positive/no	0	N/A	Yes	0	0									Naturally present in the environment.		BBPUD encourages public participation in decisions affecting drinking water quality and other matters at its Board of Directors meeting held the third Wednesday of each month at 9 A.M., 265 Doran Park Road, Bodega Bay.
Fecal Coliform or E. coli	positive sample and positive repeat sample	0	N/A	Yes	0	0									Human and animal fecal waste.		
Inorganic Constituents	MCL	PHG or MCLG	Average	Met Regulation?	Ropollo Well 1 Date of Most Recent Sample	Ropollo Well 2 Date of Most Recent Sample	Ropollo Well 3A Date of Most Recent Sample	Dunes Well 03A Date of Most Recent Sample	Dunes Well 04 Date of Most Recent Sample	Bay Flat Well Date of Most Recent Sample					Board of Directors		
Aluminum Al (ppb)	1000	600	8.33	Yes	50 12/19/2024	N/A	ND 12/31/2024	ND 12/17/2024	ND 12/11/2024	ND 10/23/2023	Erosion of natural deposits.				Rod Moore, Robert Gerber, Peter Rooney, Jerry Termini, and Joseph Conway		
Fluoride F (naturally occurring) (ppm)	2	1	0.06	Yes	0.15 12/19/2024	N/A	0.13 12/31/2024	ND 12/17/2024	0.13 12/11/2024	<1.0 10/23/2023	Erosion of natural deposits; discharge from fertilizer and aluminum factories.						
Nitrate NO3 (ppm)	45 or Nitrate	0.85	Yes	0.85	4/10/2025	1.2 1/21/2025	< .40 2/14/2025	3.1 13/10/2025	< .40 12/18/2025	< .40 12/16/2025	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits.						
Hexavalent Chromium (ppb)	10	0.02	0.43	Yes	1.21 12/19/2024	0.85 4/24/2025	ND 12/31/2024	0.565 12/17/2024	ND 12/11/2024	ND 4/24/2025					General Manager		
Organic Constituents	MCL	PHG or MCLG	Average	Met Regulation?	Ropollo Well 1 Date of Most Recent Sample	Ropollo Well 2 Date of Most Recent Sample	Ropollo Well 3A Date of Most Recent Sample	Dunes Well 03A Date of Most Recent Sample	Dunes Well 04 Date of Most Recent Sample	Bay Flat Well Date of Most Recent Sample					Janet Ames		
Total Trihalomethanes (THMs) (ppb)	80	NS	24.98	Yes	26.19 ug/L Sample Date January 28, 2025 23.71 ug/L Sample Date January 23, 2025							By product of drinking water disinfection. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience liver, kidney, or central nervous system problems, and may have an increased risk of getting cancer.		ADDITIONAL CONTACTS			
2 Constituents With Secondary MCLs	MCL	PHG or MCLG	Average	Met Regulation?	Ropollo Well 1 Date of Most Recent Sample	Ropollo Well 2 Date of Most Recent Sample	Ropollo Well 3A Date of Most Recent Sample	Dunes Well 03A Date of Most Recent Sample	Dunes Well 04 Date of Most Recent Sample	Bay Flat Well Date of Most Recent Sample					California State Water Resource Control Board, Division of Drinking Water: 707-576-2145		
Aluminum Al (ppb)	1000	600	8.33	Yes	50 12/19/2024	N/A	ND 12/31/2024	ND 12/17/2024	ND 12/11/2024	ND 10/23/2023	Erosion of natural deposits.				U.S. Environmental Protection Agency Safe Drinking Water Hotline: 800-426-4791		
Chloride Cl (ppm)	500	NS	204.00	No	260 7/9/2025	N/A	770 10/29/2025	50 7/29/2025	60 7/3/2025	85 10/23/2023	Runoff/leaching from natural deposits; seawater influence.				Sonoma County Public Health Department: 707-565-4400		
Color, color units	15	NS	1.00	Yes	<5.0 7/9/2025	N/A	<5.0 12/31/2024	<5.0 7/29/2025	<5.0 7/3/2025	5 10/23/2023	Naturally occurring organic materials.						
Odor-Threshold Odor Number (T.O.N.)	3	NS	1.42	No	< 1.0 7/9/2025	N/A	<1.0 12/31/2024	<1.0 7/29/2025	7.1 7/3/2025	< 1.0 10/23/2023	Naturally occurring organic materials.						
Turbidity (NTU)	5	NS	0.13	Yes	ND 7/9/2025	N/A	0.69 3/25/2025	ND 7/29/2025	ND 7/3/2025	ND 10/23/2023	Soil runoff				Spanish		
Specific Conductance (umhos/cm)	1600	NS	734.00	Yes	1,300 7/9/2025	N/A	690 3/25/2025	480 7/29/2025	520 7/3/2025	680 10/23/2023	Substances that form ions when in water; seawater influence.				Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.		
Sulfate SO4 (ppm)	500	NS	17.10	Yes	43 7/9/2025	N/A	18 12/31/2024	14 7/29/2025	2.9 7/3/2025	7.6 10/23/2023	Runoff/leaching from natural deposits.						
Sodium Na (ppm)	500	NS	47.20	Yes	95 7/9/2025	N/A	42 12/31/2024	25 7/29/2025	35 7/3/2025	39 10/23/2023	Salt is present in the water and is generally naturally occurring.						
Total Dissolved Solids (ppm)	1000	NS	440.00	Yes	800 7/9/2025	N/A	540 12/31/2024	250 7/29/2025	330 7/3/2025	280 10/23/2023	Runoff/leaching from natural deposits.						
3 Lead and Copper	AL	PHG	Met Regulation?		90 th Percentile Level Found		# of Sites (out of 10) found above the AL										
Copper (ppb) ***	1300	300	N/A	Yes	1.1 7/9/23		0		Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.								
Lead (ppb)	15	0.2	N/A	Yes	0.0047 7/9/23		0		Internal corrosion of household plumbing systems; discharges from industrial manufacturers; erosion of natural deposits.								
4 Other Water Quality Parameters	MCL	PHG or MCLG	Average	Met Regulation?	Ropollo Well 1 Date of Most Recent Sample	Ropollo Well 2 Date of Most Recent Sample	Ropollo Well 3A Date of Most Recent Sample	Dunes Well 03A Date of Most Recent Sample	Dunes Well 04 Date of Most Recent Sample	Bay Flat Well Date of Most Recent Sample							
Arsenic As (ppb)	10	10	ND	Yes	ND 12/19/2024	N/A	ND 12/31/2024	ND 12/17/2024	ND 12/11/2024	< 2.0 10/23/2023	Erosion of natural deposits; runoff from orchards; glass & electronics production wastes.						
Chromium Cr (ppb)	100	100	ND	Yes	ND 12/19/2024	N/A	ND 12/31/2024	ND 12/17/2024	ND 12/11/2024	ND 10/23/2023	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits.						
Total Alkalinity as CaCO3 (ppm)	N/A	N/A	N/A	N/A	190 7/9/2025	N/A	190 12/31/2024	150 7/9/2025	160 7/3/2025	200 10/23/2023	N/A						
Bicarbonate as HCO3 (ppm)	N/A	N/A	N/A	N/A	190 7/9/2025	N/A	190 12/31/2024	150 7/9/2025	180 7/3/2025	200 10/23/2023	N/A						
Hardness as CaCO3 (ppm)	N/A	N/A	N/A	N/A	386 7/9/2025	N/A	334 12/31/2024	179 7/29/2025	176 7/3/2025	190 10/23/2023	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring.						
Calcium Ca (ppm)	N/A	N/A	N/A	N/A	92 7/9/2025	N/A	77 12/31/2024	52 7/29/2025	49 7/3/2025	51 10/23/2023	N/A						
Iron Fe (ppb)	300	300	138.00	Yes	<100 7/9/2025	N/A	270 10/29/2025	<100 7/29/2025	120 7/3/2025	300 10/23/2023	Leaching from natural deposits; industrial wastes						
Magnesium Mg (ppm)	N/A	N/A	N/A	N/A	38 7/9/2025	N/A	34 12/31/2024	12 7/29/2025	1.3 7/3/2025	16 10/23/2023	N/A						
Manganese Mn (ppb)	50	50	83.60	No	62 10/28/2025	N/A	330 10/29/2025	<20 7/29/2025	<20 7/3/2025	26 10/23/2023	Leaching from natural deposits.						
pH	N/A	N/A	N/A	N/A	7.78 7/9/2025	N/A	8.26 12/31/2024	7.95 7/29/2025	7.99 7/3/2025	8.33 10/16/2025	N/A						

* Sampling schedule in accordance with BBPUD's Source Chemical Monitoring Requirements as issued by California State Water Resource Control Board.



Key Terms

DBP - disinfection by-products. These are formed when chlorine and/or ozone reacts with natural constituents in water. Trihalomethanes (THMs), haloacetic acids (HAAs) and bromate are disinfection by-products.

MCL - maximum contaminant level. The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs or MCLGs as is economically and technologically feasible. Secondary MCLs are set to protect odor, taste and appearance of drinking water.

MCLG - Maximum contaminant level goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

MRDL - Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG - Maximum residual disinfectant level goal. The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Notification level - A health-based advisory level established by the California Department of Public Health for chemicals in drinking water that lack MCLs.

Primary drinking water standard - These standards regulate contaminants that affect health by setting MCLs and MRDLs along with their monitoring, reporting and water treatment requirements.

PHG - Public Health Goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. Public health goals are set by the California Environmental Protection Agency.

Regulatory action level - The concentration which, if exceeded, triggers treatment or other requirements that a water system must follow.

TOC - Total organic carbon. A measure of organic compounds that could form by-products after disinfection.

Turbidity - A measure of the cloudiness of water. Turbidity is monitored because it is a good indication of groundwater quality and a high turbidity can hinder the effectiveness of disinfectants.

TT - Treatment technique. A required process intended to reduce the level of a contaminant in drinking water.

90th percentile - A measure that indicates 90 percent of the samples had a lower result.

Please see the attached public notification letter

A source water assessment was conducted by the California Department of Health Services in March 2002. This report is available at the District office. From the assessments it was determined that the Salmon Creek Wells are the most vulnerable to grazing, the Bodega Dunes Wells are the most vulnerable to septic systems and sewer collection systems, and the Roppolo Wells are the most vulnerable to automobile gas stations.

Disclosures required per California Drinking Water Regulations Title 22 Chapter 15 Article 20 § 64481

The source of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.

Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA / Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

