

BBPUD 2022 Annual Consumer Confidence Report

1 Primary Constituents																	CONTACT US
Microbiological Contaminants	MCL	PHG or MCLG	Average	Met Regulation?	Highest # of Detections		# of Months in Violation		Notes								Typical Source
Total Coliform in Distribution System	<1 positive/mo	0	N/A	Yes	0		0										Naturally present in the environment.
Fecal Coliform or E. coli	positive sample and positive repeat sample	0	N/A	Yes	0		0										Human and animal fecal waste.
Inorganic Constituents	MCL	PHG or MCLG	Average	Met Regulation?	Ropollo Well 1	Date of Most Recent Sample	Ropollo Well 2	Date of Most Recent Sample	Ropollo Well 3A	Date of Most Recent Sample	Dunes Well 03A	Date of Most Recent Sample	Dunes Well 4	Date of Most Recent Sample	Bay Flat Well	Date of Most Recent Sample	
Aluminum Al (ppb)	1000	600	35.60	Yes	78	12/17/2015	N/A		ND	12/8/2021	ND	12/15/2021	<50	1/2/2020	< 50	10/14/2020	
Fluoride F (naturally occurring) (ppm)	2	1	0.11	Yes	0.11	12/17/2015	N/A		ND	12/8/2021	ND	12/15/2021	0.13	12/17/2015	<1.0	10/14/2020	
Nitrate NO3 (ppm)	45 as Nitrate		0.57	Yes	0.47	12/8/2021	1	1/12/2022	< .40	2/10/2021	0.4	12/14/2022	0.4	1/6/2021	<.40	11/2/2022	
Hexavalent Chromium (ppb)	10	0.02	0.35	Yes	ND	10/26/2017	1.1	10/28/2014	ND	10/26/2017	ND	10/26/2017	ND	10/26/2017	< 1.0	10/19/2017	
Organic Constituents	MCL	PHG or MCLG	Average	Met Regulation?	Ropollo Well 1	Date of Most Recent Sample	Ropollo Well 2	Date of Most Recent Sample	Ropollo Well 3A	Date of Most Recent Sample	Dunes Well 03A	Date of Most Recent Sample	Dunes Well 4	Date of Most Recent Sample	Bay Flat Well	Date of Most Recent Sample	
Total Trihalomethanes (TTHMs) (ppb)	80	NS	11.21	Yes	12.82 ug/L Sample Date January 26, 2022 9.60 ug/L Sample Date January 26, 2022											By product of drinking water disinfection. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience liver, kidney, or central nervous system problems, and may have an increased risk of getting cancer.	
2 Constituents With Secondary MCLs	MCL	PHG or MCLG	Average	Met Regulation?	Ropollo Well 1	Date of Most Recent Sample	Ropollo Well 2	Date of Most Recent Sample	Ropollo Well 3A	Date of Most Recent Sample	Dunes Well 03A	Date of Most Recent Sample	Dunes Well 4	Date of Most Recent Sample	Bay Flat Well	Date of Most Recent Sample	
Aluminum Al (ppb)	1000	600	45.60	Yes	78	12/17/2015	N/A		ND	12/8/2021	ND	12/15/2021	<50	6/16/2016	< 50	10/14/2020	
Chloride Cl (ppm)	500	NS	182.20	Yes	330	7/20/2022	N/A		390	8/3/2022	41	7/20/2022	72	7/20/2022	78	10/14/2020	
Color, color units	15	NS	5.00	Yes	<5.0	7/20/2022	N/A		<5.0	12/8/2021	<5.0	7/20/2022	<5.0	7/20/2022	< 5.0	10/14/2020	
Odor-Threshold Odor Number (T.O.N.)	3	NS	6.00	No	< 1.0	7/20/2022	N/A		< 1.0	12/8/2021	<1.0	7/20/2022	25	7/20/2022	5	10/14/2020	
Turbidity (NTU)	5	NS	0.63	Yes	ND	7/20/2022	N/A		0.73	3/16/2022	ND	7/20/2022	ND	7/20/2022	0.65	10/14/2020	
Specific Conductance (umhos/cm)	1600	NS	988.00	No	1,500	7/20/2022	N/A		1,800	3/9/2022	390	7/20/2022	550	7/20/2022	700	10/14/2020	
Sulfate SO4 (ppm)	500	NS	19.58	Yes	54	7/20/2022	N/A		25	12/8/2021	8.2	7/20/2022	3.2	7/20/2022	7.5	10/14/2020	
Sodium Na (ppm)	500	NS	58.00	Yes	120	7/20/2022	N/A		61	12/8/2021	22	7/20/2022	37	7/20/2022	50	10/14/2020	
Total Dissolved Solids (ppm)	1000	NS	486.00	Yes	780	7/20/2022	N/A		780	12/8/2021	180	7/20/2022	240	7/20/2022	450	10/14/2020	
3 Lead and Copper	AL	PHG		Met Regulation?	90 th Percentile Level Found		Date of Most Recent Sample		# of Sites (out of 10) found above the AL								
Copper (ppb) ***	1300	300	N/A	Yes	450		August-20		0		Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.						
Lead (ppb)	15	0.2	N/A	Yes	6.4		August-20		0		Internal corrosion of household plumbing systems; discharges from industrial manufacturers; erosion of natural deposits.						
4 Other Water Quality Parameters	MCL	PHG or MCLG	Average	Met Regulation?	Ropollo Well 1	Date of Most Recent Sample	Ropollo Well 2	Date of Most Recent Sample	Ropollo Well 3A	Date of Most Recent Sample	Dunes Well 03A	Date of Most Recent Sample	Dunes Well 4	Date of Most Recent Sample	Bay Flat Well	Date of Most Recent Sample	
Arsenic As (ppb)	10	10	2.68	Yes	3	12/15/2021	N/A		3.1	12/8/2021	3.3	12/15/2021	< 2.0	12/8/2021	< 2.0	10/14/2020	
Chromium Cr (ppb)	100	100	ND	Yes	ND	12/17/2015	N/A		ND	12/8/2021	ND	12/15/2021	ND	12/17/2015	ND	10/14/2020	
Total Alkalinity as CaCO3 (ppm)	N/A	N/A	N/A	N/A	190	7/20/2022	N/A		200	12/8/2021	130	7/20/2022	180	7/20/2022	230	10/14/2020	
Bicarbonate as HCO3 (ppm)	N/A	N/A	N/A	N/A	190	7/20/2022	N/A		200	12/8/2021	130	7/20/2022	180	7/20/2022	220	10/14/2020	
Hardness as CaCO3 (ppm)	N/A	N/A	N/A	N/A	514	7/20/2022	N/A		463	12/8/2021	157	7/20/2022	197	7/20/2022	215	10/14/2020	
Calcium Ca (ppm)	N/A	N/A	N/A	N/A	120	7/20/2022	N/A		100	12/8/2021	45	7/20/2022	56	7/20/2022	57	10/14/2020	
Iron Fe (ppb)	300	300	215.00	Yes	<100	7/20/2022	N/A		<100	8/3/2022	<100	7/20/2022	150	7/20/2022	280	10/14/2020	
Magnesium Mg (ppm)	N/A	N/A	N/A	N/A	51	7/20/2022	N/A		51	12/8/2021	11	7/20/2022	14	7/20/2022	18	10/14/2020	
Manganese Mn (ppb)	50	50	74.00	No	68	10/12/2022	N/A		130	8/3/2022	<20	7/20/2022	<20	7/20/2022	24	10/14/2020	
pH	N/A	N/A	N/A	N/A	7.43	7/20/2022	N/A		7.45	12/8/2021	7.64	7/20/2022	7.87	7/20/2022	7.79	10/14/2020	



* Sampling schedule in accordance with BBPUD's Source Chemical Monitoring Requirements as issued by California State Water Resource Control Board.

For more information about water quality or to report a water quality concern, call 707-875-3332 or visit www.bodegabaypubd.com.

BBPUD encourages public participation in decisions affecting drinking water quality and other matters at its Board of Directors meeting held the third Wednesday of each month at 9 A.M., 265 Doran Park Road, Bodega Bay.

Board of Directors
 Rod Moore, Robert Gerber, Peter Rooney and Jerry Terman

General Manager
 Janet Ames

ADDITIONAL CONTACTS
 California State Water Resource Control Board, Division of Drinking Water: 707-576-2145

U.S. Environmental Protection Agency
 Safe Drinking Water Hotline: 800-426-4791

Sonoma County
 Public Health Department: 707-565-4400

Spanish

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Key Terms

DBP - disinfection by-products. These are formed when chlorine and/or ozone reacts with natural constituents in water. Trihalomethanes (THMs), haloacetic acids (HAAs) and bromate are disinfection by-products.

MCL - maximum contaminant level. The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs or MCLGs as is economically and technologically feasible. Secondary MCLs are set to protect odor, taste and appearance of

MCLG - Maximum contaminant level goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

MRDL - Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG - Maximum residual disinfectant level goal. The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Notification level - A health-based advisory level established by the California Department of Public Health for chemicals in drinking water that lack MCLs.

Primary drinking water standard - These standards regulate contaminants that affect health by setting MCLs and MRDLs along with their monitoring, reporting and water treatment requirements.

PHG - Public Health Goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. Public health goals are set by the California Environmental Protection Agency.

Regulatory action level - The concentration which, if exceeded, triggers treatment or other requirements that a water system must follow.

TOC - Total organic carbon. A measure of organic compounds that could form by-products after disinfection.

Turbidity - A measure of the cloudiness of water. Turbidity is monitored because it is a good indication of groundwater quality and a high turbidity can hinder the effectiveness of disinfectants.

TT - Treatment technique. A required process intended to reduce the level of a contaminant in drinking water.

90th percentile - A measure that indicates 90 percent of the samples had a lower result.

Please see the attached public notification letter

A source water assessment was conducted by the California Department of Health Services in March 2002. This report is available at the District office. From the assessments it was determined that the Salmon Creek Wells are the most vulnerable to grazing, the Bodega Dunes Wells are the most vulnerable to septic systems and sewer collection systems, and the Roppolo Wells are the most vulnerable to automobile gas stations.

Disclosures required per California Drinking Water Regulations Title 22 Chapter 15 Article 20 § 64481

The source of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.

Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA / Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

